



Momentum Technologies, inc.
 1507 Boettler Rd.
 Uniontown, OH 44685
 Ph: 330-896-5900
 Fax: 330-896-9943

Technical Service Report

Sealmark Mfg. Inc.

Project # PX28B1A
 Quote # 2011-120
 Date 2/28/2011
 PO# 1000-22311

Abstract: Analysis of one coating for Solar Reflectance per ASTM C1549 and Thermal Emittance per ASTM C1371.

MTI#	Description of Material	Receiving Date
MTI-110139	One panel of Sealmark #1000 Roof Coat	2/25/2011

Test	ASTM	Requirement	Result	Conclusion
Solar Reflectance	C 1549	N/A	94.7%	N/A
Thermal Emittance	C 1371	N/A	0.82	N/A

Conclusion:

Tested By:

Janna Pearson
Janna Pearson

Laboratory Technician

Reviewed By

Cindy Campbell
Cindy Campbell

Laboratory Manager

The information presented in this publication is based upon the research of Momentum Technologies, Inc. (MTI) and is to the best of its knowledge accurate. However, no guarantee of its accuracy can be made since MTI has no control over the conditions under which its products may be used by others. MTI assumes no liability for its use, or the failure of products described herein. MTI MAKES NO WARRANTIES EXPRESSED OR IMPLIED, OF MERCHANTABILITY, FITNESS, PATENT INFRINGEMENT, OR OTHERWISE. MTI SHALL NOT BE LIABLE FOR SPECIAL, INCIDENTAL AND/OR CONSEQUENTIAL DAMAGES. No statement contained herein shall be construed as a recommendation or inducement to infringe existing patents or as an endorsement of products of specific manufacturers. ALL TEST REPORTS SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT THE WRITTEN APPROVAL OF MOMENTUM TECHNOLOGIES, INC.

ISO 17025



Cert. 2711.01

